



MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SING VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D- 3896

Dated: 06/08/2024

HEALTH CERTIFICATE

1. Name of the School Spring Meadows Public School
2. School address Dewan Estate, Dwarka Mor Metro Station, Main Najafgarh Road,
New Delhi- 110059
3. No of shifts 01 (Morning) Timing 08:00 AM TO 2:00 PM
4. No of students:- Boys 2289 Girls 1829 Total 4118
5. No of staff: - Gents 20 Ladies 110 Total 130

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. Not required
- Drinking water is wholesome/ not wholesome Wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue

Dy. Health Officer
West Zone

Dy Health Officer
West Zone
MCD

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water sample collected from " Spring Meadows Public School" Dewan Estate, Dwarka Mor Metro Station Main Najafgarh Road, New Delhi -110059 vide challan No- 217 Dated-03.11.2022.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	21.11.2022
2.	Date of Analysis	-----	--	--	22.11.2022
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj
5.	Turbidity	N.T.U.	1.0	5.0	1.20
6.	PH value	-----	6.5	8.5	7.38
7.	Electrical Conductivity	µmho	--	--	396
8.	Total dissolved solids	mg/l	500	2000	194.5
CHEMICAL EXAMINATION					
9.	P th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	98
11.	Total Hardness	mg/l	200	600	136
12.	Calcium Hardness	mg/l	--	--	94
13.	Magnesium Hardness	mg/l	--	--	42
14.	Calcium as Ca	mg/l	75	200	37.6
15.	Magnesium as Mg	mg/l	30	100	10.08
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	--	NIL
18.	Nitrate as No ₃	mg/l	45	N.R.	3.8
19.	Sulphate	mg/l	200	400	40
20.	Chloride	mg/l	250	1000	28
21.	Dissolved Iron	mg/l	0.3	N.R.	0.08
22.	Fluoride	mg/l	1	1.5	0.06
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	0.25
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS : As per tested parameters sample -S1 can be use for drinking purpose.

S. Prasad
23/12/22
Chemist

S. Prasad
ACWA
ASST. CHIEF WATER ANALYST